



#### NOTES:

1. Backfill of trench from top of #57 Crushed Stone Bedding to the top of trench shall be Compacted to 95% maximum dry density in accordance with Section 911. No grits will be allowed.
2. The compaction requirement will be strictly enforced by the City.
3. The C of the proposed storm sewer should be offset from the property line.
4. The cost of the #57 Crushed Stone Bedding, Compacted Fill and Backfill shall be included in item 901.
5. Minimum width of trench and quantities are as shown on drawings AA-S149, AA-S151, or AA-S152.

*[Signature]*  
STORMWATER PROGRAM MANAGER

*[Signature]*  
ADMINISTRATOR

12/15/93  
APPROVED

REVISED

### TYPICAL TRENCH DETAIL FOR STORM SEWERS OUTSIDE R/W WITH COVER 30" OR LESS

CITY OF COLUMBUS, OHIO  
DEPARTMENT OF PUBLIC UTILITIES  
DIVISION OF SEWERAGE & DRAINAGE

STANDARD  
CONSTRUCTION DRAWING

DR. W.C.K.  
CK. DJH

SHEET 1  
OF 1

FILE NO.  
AA-S155